Sr. No.: SP-2403

Date: 25/09/2026

HEALTH AND HYGIENE CERTIFICATE

It is certified that an inspection of **Orchids The International School**, located at Mahapura, Jaipur, was conducted by the Health Section.

Upon inspection, it is verified that the institution provides **safe drinking water facilities** for all students and staff members, and consistently maintains **hygienic and sanitary conditions** throughout the school building and campus grounds.

This certificate is issued pursuant to the application submitted by the Principal of Orchids The International School.

- **Validity Period:** One (1) year from the date of issuance.
- **Academic Session:** 2026–2027

चिकित्सा अधिकारी
Signature & Seal
हरियक्ष कावटिया राजकीय चिकित्सालय
शास्त्री नगर, जयपुर
Health Officer
Central Zone, Jaipur

(DR. RAHUL BHARGAVA)
(Medical officer)
R.N.O → 29710

Manager
Orchids The International School
Khatwara Mahapura, Jaipur

PRINCIPAL
ORCHIDS THE INTERNATIONAL SCHOOL
NEVTA, JAIPUR

Nimawat Education Society
Authorised Signatory

Scanned with OKEN Scanner

OFFICE OF THE CHIEF CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT, RAJASTHAN, JAIPUR

REPORT OF THE CHEMICAL EXAMINATION OF WATER

Report No.: Raj/DW(Chem)/2026-27/ 1362-63 Dated : 8/9/26

The sample was not collected by this laboratory

Issued To,

Principal
Orchids The International School, Nevta
Jaipur

District: Jaipur
Block/City: Sanganer

Not Valid for Water Quality Legal Cases

Ref. ID :	15	Lab Sample No. :	19	20
Reference : Your Letter No. :	118	Source :	Treated Water	TW
Reference Dated :	02-09-2026	Source Location :	RO, OIS School Campus	OIS School Campus
Date of Receipt :	02-09-2026	Habitation/Ward No. :	Mahapura	Mahapura
Name of Sample Taker :	Vinod Meena	Village/Colony/Town :	Mahapura	Mahapura
Desig. of Sample Taker :	-	Gram Panchayat/City Area :	Mahapura	Mahapura
Latitude :		Date of Collection :	02-09-2026	02-09-2026
Longitude :		Date of Examination :	07-09-2026	07-09-2026

IS-10500:2012

Test Parameters	Requirement (Acceptable Limit)	Permissible limit in the absence of alternative sources	Test Values of Samples	
1 pH	6.5 to 8.5	No Relaxation	7.8	7.8
2 Turbidity(NTU)	1	5	Clear	Clear
3 Colour (Hazen Unit)	5	15	None	None
4 Odour	Unobjectionable	-	UO	UO
5 Total Alkalinity (as $CaCO_3$)	200	600	60	110
6 Total Hardness (as $CaCO_3$)	300	600	70	270
7 Calcium (as Ca++)	75	200	8	44
8 Magnesium (as Mg++)	30	100	12	39
9 Chloride (as Cl^-)	600	1000	40	80
10 Sulphate (as SO_4^{-2})	200	400	3	15
11 Nitrates (as NO_3)	45	No Relaxation	17	130
12 Fluoride (as F^-)	1.0	1.50	0.10	0.11
13 Total Dissolved Solids	500	2000	210	595
14 Residual Chlorine	0.2	0.5	Nil	Nil

Note:- *Report is not valid for Food Liecence or any Certificate.*

8/9/2026
Superintending Chemist
PHED, Lab, Jaipur

Report No.: Raj/DW(Chem)/2026-27/
Copy to:
1. The Chief Chemist, Public Health Engineering Department, Rajasthan, Jaipur.

Dated:

Manager
Orchids The International School
Khatwara Mahapura, Jaipur

Nimawat Education Society

PRINCIPAL
ORCHIDS THE INTERNATIONAL SCHOOL
NEVTA, JAIPUR

Authorised Signatory

Superintending Chemist

OFFICE OF THE CHIEF CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT, RAJASTHAN, JAIPUR

REPORT OF THE BACTERIOLOGICAL EXAMINATION OF WATER

Report No.: Raj/DWt/Bact/2026-27/ 1768 Dated: 8/9/26

To,

Principal
Orchids The International School, Nevta
Jaipur

The sample was not collected by this laboratory

District : Jaipur
Block/City : Sanganer

Not Valid for Water Quality Legal Cases

Reference Your Letter No. 118 Dated: 02-09-2026
Date of Receipt : 02-09-2026 Ref. ID: 7
Date of Examination : 02-09-2026

Name & Designation of Sample Taker
Vinod Meena

Lab Sample No.	Date & Time of Collection	Village/Town	Source	Location	Residual Chlorine (mg/l)	Total Coli Form/100 ml.	E-Coli/ 100 ml.	Remark
9	02-09-2026	Mahapura	Treated Water	RO, OIS School Campus	-	0	-	Satisfactory ~~REF~~
10	02-09-2026	Mahapura	TW	OIS School Campus	-	0	-	Satisfactory

Manager
Orchids The International School
Khatwara Mahapura, Jaipur

8/9/2026
Superintending Chemist
PHED, Lab, Jaipur

Report No.: R... Dated:

Copy to:
1. The Chief Chemist, Public Health Engineering Department, Rajasthan, Jaipur.
0

PRINCIPAL
ORCHIDS THE INTERNATIONAL SCHOOL
NEVTA, JAIPUR

Superintending Chemist

Nimawat Education Society

Authorised Signatory